

MOXIE POWER GENERATION LIMITED

MPGL/ENV/TNPCB/2024-25/31

09.01.2025

To

The Member Secretary,
Tamil Nadu Pollution Control Board,
76, Anna Salai, Guindy,
Chennai - 600 032.

Dear Sir,

Sub: Submission of Monthly Environment report - Reg.

This has reference to the captioned subject; we enclose the Monthly Environment Report of Moxie Power Generation Ltd (formerly Coastal Energen Pvt Ltd) 2 x 600 MW Thermal Power Plant, Tuticorin for the period of 01.12.2024 to 31.12.2024.

This is for your kind information and records.

Thanking You,
Yours faithfully,
For MOXIE POWER GENERATION LIMITED



MK Parameswaran

Station Head



Copy to: 1. Joint Chief Environmental Engineer (M), TNPCB, Tirunelveli
2. District Environmental Engineer, TNPCB, Tuticorin

Moxie Power Generation Limited
"Adani Corporate House"
Shantigram, Near Vaishno Devi Circle,
S. G. Highway, Khodiyar,
Ahmedabad-382421, Gujarat India
CIN: U35100TN2024PLC167065

Tel +91 79 2656 7555
Fax +91 79 2555 7177

Registered Office: "Ramcon Fortuna Towers 4th, Kodambakkam High Road, Nungambakkam High Road, Chennai – 600034

MOXIE POWER GENERATION LIMITED

2 X 600 MW THERMAL POWER PLANT

METEOROLOGICAL STATION REPORT

Daily Average from 01.12.2024 to 31.12.24

Date	Ambient Temperature (°C)			Barometric Pressure (m.bar)			Predominant Wind direction Blowing from	Wind Speed (Km/Hr)			Relative Humidity (%)			Rain Fall (mm)
	Min	Max	Avg	Min	Max	Avg		Min	Max	Avg	Min	Max	Avg	
	1-Dec-24	25.7	30.7	28.4	1034.0	1036.7		1035.2	North & North East	1.2	22.3	9.7	54.1	
2-Dec-24	24.7	34.3	28.8	1034	1037.9	1035.8	East & North East	1.2	22.5	8.0	52.5	91.8	73.8	0.0
3-Dec-24	24.3	33.4	25.7	1036.5	1039.2	1037.7	North & East	1.2	18.3	6.1	56	95.7	79.9	0.5
4-Dec-24	23.6	32.4	23.6	1037.6	1040.3	1038.9	North & North West	1.2	20.0	6.4	61.8	99.5	84.4	0.0
5-Dec-24	23.5	33.2	22.4	1038	1041	1039.6	North & West	1.2	15.4	5.9	60.3	99.5	86.3	3.0
6-Dec-24	22.8	33	26.4	1037.6	1041.2	1038.9	North & South West	1.2	19.7	5.6	56.3	99.5	73.4	0.0
7-Dec-24	23.1	32.6	24.6	1036.4	1040.6	1038.3	North & West	1.2	18.8	4.9	60.2	91.6	44.4	0.0
8-Dec-24	23	33.2	27.3	1037.9	1040.9	1039.4	North & West	1.2	17.3	5.8	49.3	99.5	81.6	0.0
9-Dec-24	22.9	33.1	27.3	1037.5	1040.6	1039.1	North & West	1.2	16.6	5.7	57.7	99.2	82.2	0.0
10-Dec-24	23.4	34.1	27.7	1036.8	1040.3	1038.8	West & South West	1.2	19.9	5.3	47.7	98.8	78.5	0.0
11-Dec-24	22.9	30.5	26.6	1037.1	1040.3	1038.6	West & South West	1.2	27.3	9.1	59.6	97.4	78.3	0.0
12-Dec-24	22.7	26.2	24.3	1035.7	1039	1037.5	West & South West	1.9	22.3	10.1	76.2	99.5	96.1	107.0
13-Dec-24	23.9	29.5	25.7	1036.4	1040.3	1038.4	North & North West	1.2	27.1	7.7	81.0	99.5	95.5	22.0
14-Dec-24	21.7	29.3	23.1	1038.4	1042	1040.2	West & South West	1.2	22.1	6.7	89.8	99.5	96.9	18.5
15-Dec-24	21.8	30.5	25.4	1039.1	1041.7	1040.5	West & South West	1.2	21.4	7.7	57.5	99.5	81.8	0.0
16-Dec-24	23.3	29.7	26	1038.2	1041.3	1039.9	West & North West	1.2	21.0	6.3	57.8	89.8	77.4	0.0
17-Dec-24	22.8	32.5	26.6	1037.4	1040.4	1039.1	West & South West	1.2	13.6	4.2	57.6	92.2	79.8	0.0
18-Dec-24	23.8	32	27.2	1037	1039.9	1038.4	North & South West	1.2	15.3	4.8	68.2	99.5	87.6	0.0
19-Dec-24	23.8	32.4	27.6	1036.6	1039.9	1038.4	North & North East	1.2	14.5	5.3	64	99.5	86.3	0.0
20-Dec-24	23.2	33.9	28	1036.6	1039.6	1038.1	North & North East	1.2	20.6	6.0	61.2	99.5	83.3	0.0
21-Dec-24	23.5	32.7	27.6	1037	1040.2	1038.5	North & North West	1.2	16.3	4.9	64.1	99.5	86.5	0.0
22-Dec-24	23	32.9	27.2	1037.5	1040.6	1039.2	North West & South West	1.2	16.6	5.8	65.4	99.5	86.6	0.0
23-Dec-24	23.4	32.8	26.3	1037.9	1041.4	1039.5	North West & South West	1.2	14.9	4.5	58.5	99.5	88.0	1.5
24-Dec-24	22.5	32.4	26.7	1037.6	1040.8	1039.3	North & North West	1.2	17.1	5.4	59.4	99.5	82.5	0.0
25-Dec-24	21	34.3	26.6	1037.9	1041.3	1039.7	North West & South West	1.2	14.0	4.2	45.5	99.5	79.8	0.0
26-Dec-24	22.2	33.3	27.3	1038.9	1042.3	1040.7	North West & South West	1.2	15.8	5.1	55.5	99.5	82.0	0.0
27-Dec-24	24.2	32.2	27.7	1039.6	1042.7	1041.3	West & South West	1.2	17.8	7.4	65.4	99.4	82.7	9.0
28-Dec-24	23.5	32	26.9	1039.8	1043.1	1041.4	West & South West	1.2	18.6	7.5	50	95	77.3	0.0
29-Dec-24	23.2	32.5	27.5	1038.8	1042.8	1040.9	West & North West	1.8	18.4	8.3	53.5	97.1	76.3	0.0
30-Dec-24	24.2	31.8	26.7	1039	1042.3	1040.7	West & North West	1.8	22.1	9.7	64.5	96.2	83.9	1.0
31-Dec-24	24	29.5	25.8	1038.8	1042.4	1040.7	West & South West	1.4	22.7	9.6	75	98	89.1	6.5

Total Rainfall for the month 102.5 mm. Rainfall Recorded on 3, 5, 12, 13, 14, 23, 27, 30 & 31 December.

Remarks:



For Moxie Power Generation Limited
 MK Parameswaran
 Station Head

MOXIE POWER GENERATION LIMITED

2 X 600 MW THERMAL POWER PLANT

CONTINUOUS AMBIENT AIR QUALITY MONITORING REPORT

Daily Average from 01.12.2024 to 31.12.2024

Date	STATION-1 (Near Main Office)					STATION-2 (Near Batching Plant)					STATION-3 (Near Crusher House)					STATION-4 (Sea Water Pump House)				
	SO2 µg/m ³	NO2 µg/m ³	PM10 µg/m ³	PM2.5 µg/m ³	CO mg/m ³	SO2 µg/m ³	NO2 µg/m ³	PM10 µg/m ³	PM2.5 µg/m ³	CO mg/m ³	SO2 µg/m ³	NO2 µg/m ³	PM10 µg/m ³	PM2.5 µg/m ³	CO mg/m ³	SO2 µg/m ³	NO2 µg/m ³	PM10 µg/m ³	PM2.5 µg/m ³	CO mg/m ³
1-Dec-24	7.6	8.4	75.0	37.0	0.8	9.6	22.8	37	10.0	0.6	6.7	12.5	21.0	10.0	0.2	9.7	8.6	85.0	*	0.6
2-Dec-24	8.4	8.4	68.0	42.0	0.7	9.7	26.5	23	23.0	0.6	6.8	17.0	28.0	12.0	0.4	9.7	7.9	84.0	*	0.7
3-Dec-24	8.1	7.2	63.0	36.0	0.6	9.3	21.3	24	16.0	0.5	6.6	13.2	24.0	11.0	0.3	9.1	7.4	74.0	*	0.6
4-Dec-24	9.7	3.6	125.0	41.0	0.6	9.6	24.4	26	11.0	0.6	7.1	15.7	18.0	8.0	0.9	9.2	9.6	86.0	*	0.5
5-Dec-24	8.9	3.6	76.0	15.0	0.7	9.9	18.9	51	13.0	0.9	6.9	13.7	10.0	18.0	0.8	9.6	8.6	62.0	*	0.5
6-Dec-24	8.7	3.6	68.0	11.0	0.6	10.1	14.6	62	14.0	0.6	7.1	11.8	12.0	12.0	0.6	9.1	9.2	42.0	*	0.5
7-Dec-24	8.6	3.6	65.0	14.0	0.6	10.3	15.2	22	16.0	0.6	6.7	12.6	15.0	14.0	0.6	9.3	9.3	44.0	*	0.6
8-Dec-24	8.4	3.6	78.0	26.0	0.7	10.4	16.5	33	12.0	0.6	6.8	13.2	17.0	16.0	0.4	9.0	9.4	56.0	*	0.6
9-Dec-24	8.4	3.6	114.0	54.0	0.7	10.4	16.2	19	36.0	0.7	6.7	14.6	28.0	12.0	0.4	9.3	9.1	101.0	*	0.7
10-Dec-24	8.0	3.5	91.0	58.0	0.8	10.5	16.8	51	17.0	0.7	6.8	14.9	38.0	17.0	0.5	9.6	4.1	109.0	*	0.8
11-Dec-24	8.2	3.5	86.0	52.0	0.8	10.4	16.3	14	12.0	0.7	6.6	14.3	37.0	16.0	0.6	9.7	9.2	106.0	*	0.8
12-Dec-24	8.7	3.5	64.0	26.0	0.5	10.3	16.2	24	6.0	0.6	6.7	13.4	11.0	21.0	0.4	9.9	8.2	66.0	*	0.7
13-Dec-24	9.2	3.5	70.0	10.0	0.9	10.6	10.7	10	51.0	0.5	6.6	12.1	23.0	20.0	0.4	9.7	9.4	61.0	*	0.6
14-Dec-24	8.5	3.6	90.0	45.0	0.9	10.6	12.2	17	34.0	0.5	6.8	12.5	26.0	12.0	0.5	10.0	9.3	81.0	*	0.8
15-Dec-24	8.1	3.5	92.0	53.0	0.9	10.5	8.7	16	11.0	0.5	6.8	12.4	29.0	12.0	0.3	9.7	8.9	85.0	*	0.8
16-Dec-24	8.2	3.4	91.0	47.0	0.9	10.5	8.9	31	23.0	0.5	6.8	11.6	37.0	16.0	0.4	9.1	9.1	107.0	*	0.9
17-Dec-24	8.1	3.5	94.0	41.0	0.9	10.7	16.5	24	39.0	0.5	7.0	11.5	62.0	18.0	0.4	8.8	8.6	154.0	*	1.0
18-Dec-24	7.7	3.5	93.0	46.0	0.9	11.4	40.9	65	25.0	0.4	7.0	12.0	36.0	16.0	0.3	8.9	8.4	142.0	*	0.9
19-Dec-24	8.2	3.5	96.0	49.0	0.9	11.5	39.9	57	13.0	0.4	7.2	14.5	28.0	10.0	0.4	8.6	8.3	69.0	*	0.9
20-Dec-24	8.5	3.5	115.0	52.0	0.9	11.5	36.6	39	11.0	0.3	7.4	13.9	30.0	9.0	0.3	9.7	7.9	68.0	34.0	0.9
21-Dec-24	6.8	3.9	108.0	42.0	0.7	11.6	36.0	35	7.0	0.3	7.8	13.2	21.0	8.0	0.3	8.4	11.6	70.0	44.0	0.8
22-Dec-24	4.8	4.8	93.0	45.0	0.8	11.6	35.0	38	8.0	0.3	8.5	13.3	18.0	7.0	0.3	7.6	10.4	55.0	43.0	0.8
23-Dec-24	5.1	4.7	91.0	52.0	0.8	11.7	29.7	43	42.0	0.2	7.5	14.6	21.0	6.0	0.2	7.2	10.2	79.0	37.0	0.8
24-Dec-24	5.2	4.8	75.0	40.0	0.9	11.8	24.9	33	13.0	0.3	6.1	13.7	27.0	10.0	0.6	6.9	11.2	86.0	48.0	0.8
25-Dec-24	4.9	4.7	51.0	36.0	0.8	11.8	26.1	26	12.0	0.2	6.0	12.5	30.0	10.0	0.6	6.5	10.0	73.0	33.0	0.7
26-Dec-24	5.3	4.8	23.0	34.0	0.9	11.7	26.3	55	15.0	0.3	5.6	12.5	31.0	11.0	0.6	6.4	9.6	99.0	62.0	0.7
27-Dec-24	5.2	4.9	22.0	22.0	0.9	12.1	26.2	19	41.0	0.3	5.9	12.6	14.0	5.0	0.5	5.4	8.6	53.0	25.0	0.7
28-Dec-24	5.2	4.9	27.0	25.0	0.9	12.1	27.3	33	17.0	0.3	5.6	13.5	18.0	11.0	0.5	5.6	7.7	61.0	26.0	0.7
29-Dec-24	5.1	4.8	45.0	49.0	0.9	12.6	26.8	47	6.0	0.4	5.7	14.5	24.0	10.0	0.5	5.6	7.8	68.0	41.0	0.7
30-Dec-24	5.1	4.8	30.0	32.0	0.9	12.9	29.1	21	23.0	0.4	5.5	13.9	18.0	7.0	0.5	5.7	5.8	47.0	25.0	0.8
31-Dec-24	5.0	5.0	43.0	37.0	0.9	13.1	22.3	53	28.0	0.4	5.5	14.0	24.0	11.0	0.6	5.1	8.4	87.0	56.0	1.1

* Due to Analyser problem data not received.

Remarks:

For Moxie Power Generation Limited



Gnanam

MK Parameswaran
Station Head

MOXIE POWER GENERATION LIMITED



2 X 600 MW THERMAL POWER PLANT

STACK EMISSION MONITORING REPORT

Daily Average from 01.12.2024 to 31.12.2024

Date	UNIT-1			UNIT-2		
	PM (50 mg/m3)	SO2 (200 mg/m3)	Nox (450 mg/m3)	PM (50 mg/m3)	SO2 (200 mg/m3)	Nox (450 mg/m3)
1-Dec-24				31	83	79
2-Dec-24	41	182	157	35	89	83
3-Dec-24	40	181	110	Unit not in operation		
4-Dec-24	38	124	76	45	78	114
5-Dec-24	38	86	0	45	111	88
6-Dec-24	Unit not in operation			45	174	95
7-Dec-24				45	190	95
8-Dec-24				45	156	99
9-Dec-24				45	178	107
10-Dec-24				45	171	107
11-Dec-24				45	158	111
12-Dec-24				46	144	116
13-Dec-24				47	131	134
14-Dec-24	31	121	49	46	101	141
15-Dec-24	40	133	52	46	89	135
16-Dec-24	43	137	69	46	104	172
17-Dec-24	41	137	68	46	112	169
18-Dec-24	39	157	94	46	59	56
19-Dec-24	36	155	93	Unit not in operation		
20-Dec-24	38	154	84			
21-Dec-24	40	147	94			
22-Dec-24	36	143	99	40	67	125
23-Dec-24	41	153	94	46	100	154
24-Dec-24	40	155	96	46	125	216
25-Dec-24	41	157	101	46	168	167
26-Dec-24	40	146	93	46	92	98
27-Dec-24	39	114	89	46	163	81
28-Dec-24	42	101	81	46	166	86
29-Dec-24	41	100	74	46	157	75
30-Dec-24	39	106	83	46	162	83
31-Dec-24	41	98	86	46	104	80
Remarks:	* Nil					

For Moxie Power Generation Limited



MK Parameswaran
 Station Head

MOXIE POWER GENERATION LIMITED
2 X 600 MW THERMAL POWER PLANT
CONTINUOUS EFFLUENT MONITORING SYSTEM REPORT
Daily Average from 01.12.2024 to 31.12.2024

Date	ETP TREATED WATER QUALITY			STP - 1 (10 KLD)				STP - 2 (40 KLD)			
	Temp (40 °C)	TSS (100 mg/Lit)	pH (5.5 to 9)	pH (6.5 to 9)	TSS (30 mg/Lit)	COD	BOD (20 mg/Lit)	pH (6.5 to 9)	TSS (30 mg/Lit)	COD	BOD (20 mg/Lit)
1-Dec-24	23.1	8.0	8.7	6.7	1.7	21.3	10.6	8.2	26.1	1.1	0.3
2-Dec-24	23.9	9.6	8.6	7.3	8.6	15.8	7.8	7.7	20.4	0.5	0.2
3-Dec-24	24.4	13.3	8.6	8.2	6.2	8.5	4.3	7.5	21.9	0.2	0.1
4-Dec-24	24.3	10.4	8.7	6.7	4.2	3.2	1.1	7.8	19.3	0.2	0.1
5-Dec-24	23.2	6.9	8.4	6.9	0.2	0.2	0.1	7.3	22.7	0.2	0.1
6-Dec-24	24.3	6.7	8.6	6.9	3.2	14.7	7.3	6.9	13.6	0.2	0.1
7-Dec-24	24.1	6.8	8.3	6.4	4.3	17.4	9.4	6.9	2.6	0.2	0.1
8-Dec-24	24.1	6.9	7.0	6.4	0.5	1.2	0.5	7.1	1.3	0.2	0.1
9-Dec-24	23.9	7.0	5.7	6.4	8.9	10.2	21.3	7.6	3.8	0.2	0.1
10-Dec-24	23.8	7.0	5.8	6.2	14.6	12.8	5.7	8.2	3.6	0.2	0.1
11-Dec-24	22.7	8.0	5.8	*	6.7	12.3	5.4	7.7	12.3	16.3	9.8
12-Dec-24	20.4	9.1	5.8	*	7	12.1	5.7	7.9	13.6	39.4	18.6
13-Dec-24	21.4	10.4	5.7	*	12.3	14.2	6.8	7.6	14.3	36.2	17.2
14-Dec-24	19.6	11.7	5.8	*	4.8	15.7	7.8	7.5	16.3	33.4	16.5
15-Dec-24	22.4	13.2	6.0	*	6.3	17.3	8.3	7.4	17.4	17.3	8.7
16-Dec-24	21.0	14.0	6.2	*	7.2	8.3	4.1	7.3	18.6	16.3	8.6
17-Dec-24	24.4	6.9	6.4	*	8.5	3.6	1.6	7.2	1.2	2.1	0.9
18-Dec-24	23.4	6.9	6.5	*	7.3	2.1	1	7.4	0.5	3.5	1.4
19-Dec-24	23.8	6.8	6.4	6.7	8.9	3.1	1.4	7.6	1.6	2.2	1.3
20-Dec-24	24.0	6.8	6.5	6.6	0.4	8.7	4.3	7.4	0.5	1.8	0.7
21-Dec-24	24.3	8.5	6.4	6.7	3.6	11.3	5.6	7.3	1.2	1.6	0.7
22-Dec-24	23.6	18.9	6.5	6.7	0.4	11.7	5.8	7.2	3.6	1.8	0.8
23-Dec-24	22.8	19.9	6.6	6.8	0.6	12.8	6.4	7.6	1.6	2.5	1.2
24-Dec-24	23.1	15.6	6.7	6.7	0.4	14.1	7.1	7.4	2.5	1.8	0.8
25-Dec-24	23.2	6.7	6.6	6.8	0.4	20.3	10.4	7.6	1.8	1.4	0.6
26-Dec-24	24.1	9.6	6.4	6.8	0.3	28.4	14.2	7.4	10.2	1.2	0.5
27-Dec-24	24.0	6.5	6.3	6.6	0.6	27.1	13.6	8.2	5.8	14.9	7.5
28-Dec-24	23.4	6.5	6.2	6.7	0.3	28.2	14.1	8.1	6.1	32.1	16.0
29-Dec-24	24.0	6.8	6.5	6.8	0.2	27.0	13.5	8.3	4.3	34.2	17.2
30-Dec-24	23.0	6.8	6.5	6.7	1.3	23.3	11.7	8.4	2.1	34.9	17.5
31-Dec-24	23.2	6.6	6.8	6.7	1.8	23.8	11.4	8.2	3.1	33.1	17.2
Remarks:	* Due to pH sensor issue, data not received.										

For Moxie Power Generation Limited

MK Parameswaran
MK Parameswaran
Station Head



MOXIE POWER GENERATION LIMITED

2 X 600 MW THERMAL POWER PLANT

DAILY EFFLUENT DISCHARGE FROM 01.12.2024 to 31.12.2024

DATE	ETP TREATED WATER (m3)	STP-1 TREATED WATER (m3)	STP-2 TREATED WATER (m3)
1-Dec-24	*	2.1	2.5
2-Dec-24	*	3.2	2.6
3-Dec-24	*	6.3	2.0
4-Dec-24	*	5.4	1.8
5-Dec-24	*	5.2	3.0
6-Dec-24	112.0	3.3	2.3
7-Dec-24	96.0	5.7	0.7
8-Dec-24	62.0	1.9	1.8
9-Dec-24	*	5.2	2.5
10-Dec-24	*	4.9	1.9
11-Dec-24	*	3.6	1.0
12-Dec-24	*	4.9	0.9
13-Dec-24	*	2.0	0.9
14-Dec-24	*	3.9	0.5
15-Dec-24	*	1.9	0.6
16-Dec-24	97.0	1.3	0.4
17-Dec-24	*	6.3	3.0
18-Dec-24	*	4.0	2.5
19-Dec-24	100.0	6.0	2.2
20-Dec-24	128.0	2.9	1.5
21-Dec-24	*	3.9	2.7
22-Dec-24	*	3.9	2.3
23-Dec-24	*	4.2	2.3
24-Dec-24	56.0	2.1	2.7
25-Dec-24	*	1.7	1.9
26-Dec-24	*	1.3	2.3
27-Dec-24	77.0	1.0	2.0
28-Dec-24	133.0	0.6	1.0
29-Dec-24	144.0	0.0	0.9
30-Dec-24	*	1.7	1.7
31-Dec-24	*	2.7	2.5
Remarks:	* No Effluent Generation.		

For Moxie Power Generation Limited

MK Parameswaran
Station Head



MOXIE POWER GENERATION LIMITED

2 X 600 MW THERMAL POWER PLANT

SEA WATER INTAKE & OUTFALL TEMPERATURE DIFFERENCE FROM 01.12.2024 TO 31.12.2024

Date	Sea Water Intake	Sea Water Outfall	Difference
1-Dec-24	28.3	31.7	3.4
2-Dec-24	28.3	32.4	4.1
3-Dec-24	28.6	32	3.4
4-Dec-24	28.6	32.1	3.5
5-Dec-24	28.9	32	3.1
6-Dec-24	29.3	32.6	3.3
7-Dec-24	29.3	32.5	3.2
8-Dec-24	29.3	32.6	3.3
9-Dec-24	29.2	32.4	3.2
10-Dec-24	29.1	32.3	3.2
11-Dec-24	28.7	31.9	3.2
12-Dec-24	27.9	30.8	2.9
13-Dec-24	28.2	30.7	2.5
14-Dec-24	28	30.3	2.3
15-Dec-24	27.9	30.9	3.0
16-Dec-24	28	30.9	2.9
17-Dec-24	28.2	31.6	3.4
18-Dec-24	28.6	31.7	3.1
19-Dec-24	28.6	32.2	3.6
20-Dec-24	28.8	32.6	3.8
21-Dec-24	29.1	32.5	3.4
22-Dec-24	28.9	32.1	3.2
23-Dec-24	28.5	31.7	3.2
24-Dec-24	28.6	31.9	3.3
25-Dec-24	28.8	32.4	3.6
26-Dec-24	28.8	32.3	3.5
27-Dec-24	28.8	32.1	3.3
28-Dec-24	28.7	31.8	3.1
29-Dec-24	28.7	31.9	3.2
30-Dec-24	28.5	31.4	2.9
31-Dec-24	27.9	30.4	2.5

Remarks: Temperature difference of sea water intake and outfall temperature were with in the prescribed Limit of 5°C.

For Moxie Power Generation Limited

MK Parameswaran
Station Head

